



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Hollis School
554 River Road
Hollis, ME 04042

Date Printed: 02/11/2022
Work Order #: 2202-01055
Client Job #: 593
Date Received: 02/09/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 02/11/2022
CLIENT NAME: Hollis School

CLIENT ADDRESS: 554 River Road
Hollis, ME 04042

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 02/09/2022 09:15AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 19° CELSIUS
CLIENT JOB #: 593

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2202-01055-001	Upper drinking fountain by room #2	I	DWF	02/03/2022 05:29AM	4.7	ppb			DG-NH	02/10/2022 06:13PM
2202-01055-002	Lower drinking fountain by room #2	I	DWF	02/03/2022 05:28AM	4.2	ppb			DG-NH	02/10/2022 06:16PM
2202-01055-003	Drinking fountain by room #5	I	DWF	02/03/2022 05:32AM	<1	ppb			DG-NH	02/10/2022 06:20PM
2202-01055-004	Bottle fill by room #5	I	DWF	02/03/2022 05:33AM	<1	ppb			DG-NH	02/10/2022 06:24PM
2202-01055-005	Portable 1 faucet	I	OT	02/03/2022 05:37AM	<1	ppb			DG-NH	02/10/2022 06:27PM
2202-01055-006	Faucet room #9	I	OT	02/03/2022 05:34AM	8.9	ppb			DG-NH	02/10/2022 06:31PM
2202-01055-007	Faucet room #10	I	OT	02/03/2022 05:31AM	3.2	ppb			DG-NH	02/10/2022 06:34PM
2202-01055-008	Kitchen prep sink faucet	I	KF	02/03/2022 05:27AM	<1	ppb			DG-NH	02/10/2022 06:38PM
2202-01055-009	Faucet room #12	I	OT	02/03/2022 05:42AM	1.7	ppb			DG-NH	02/10/2022 06:42PM
2202-01055-010	Drinking fountain room #12	I	DWF	02/03/2022 05:40AM	1.6	ppb			DG-NH	02/10/2022 06:45PM
2202-01055-011	Faucet room #13	I	OT	02/03/2022 05:50AM	<1	ppb			DG-NH	02/10/2022 07:03PM
2202-01055-012	Drinking fountain room #13	I	DWF	02/03/2022 05:48AM	1.1	ppb			DG-NH	02/10/2022 07:07PM
2202-01055-013	Faucet A room #14	I	OT	02/03/2022 05:53AM	2.0	ppb			DG-NH	02/10/2022 07:10PM
2202-01055-014	Faucet B room #14	I	OT	02/03/2022 05:56AM	5.2	ppb			DG-NH	02/10/2022 07:14PM
2202-01055-015	Faucet room #15	I	OT	02/03/2022 06:09AM	3.3	ppb			DG-NH	02/10/2022 07:18PM
2202-01055-016	Drinking fountain room #15	I	DWF	02/03/2022 06:08AM	4.3	ppb			DG-NH	02/10/2022 07:21PM
2202-01055-017	Faucet room #16	I	OT	02/03/2022 06:10AM	3.1	ppb			DG-NH	02/10/2022 07:25PM
2202-01055-018	Drinking fountain room #16	I	DWF	02/03/2022 06:11AM	1.4	ppb			DG-NH	02/10/2022 07:29PM
2202-01055-019	Faucet room #17	I	OT	02/03/2022 06:13AM	2.8	ppb			DG-NH	02/10/2022 07:43PM
2202-01055-020	Drinking fountain room #17	I	DWF	02/03/2022 06:13AM	1.9	ppb			DG-NH	02/10/2022 07:47PM
2202-01055-021	Faucet room #18	I	OT	02/03/2022 06:16AM	1.3	ppb			DG-NH	02/10/2022 07:58PM
2202-01055-022	Drinking fountain room #18	I	DWF	02/03/2022 06:14AM	2.1	ppb			DG-NH	02/10/2022 08:01PM
2202-01055-023	Faucet room #19	I	OT	02/03/2022 06:17AM	1.6	ppb			DG-NH	02/10/2022 08:05PM
2202-01055-024	Drinking fountain room #19	I	DWF	02/03/2022 06:18AM	1.1	ppb			DG-NH	02/10/2022 08:08PM

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 02/11/2022
CLIENT NAME: Hollis School

CLIENT ADDRESS: 554 River Road
 Hollis, ME 04042

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 02/09/2022 09:15AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 19° CELSIUS
CLIENT JOB #: 593

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2202-01055-025	Faucet Room #20	I	OT	02/03/2022 06:19AM	1.3	ppb			DG-NH	02/10/2022 08:12PM
2202-01055-026	Drinking fountain room #20	I	DWF	02/03/2022 06:20AM	<1	ppb			DG-NH	02/10/2022 08:16PM
2202-01055-027	Faucet room #21	I	OT	02/03/2022 06:22AM	1.1	ppb			DG-NH	02/10/2022 08:26PM
2202-01055-028	Drinking fountain room #21	I	DWF	02/03/2022 06:21AM	1.8	ppb			DG-NH	02/10/2022 08:30PM
2202-01055-029	Faucet room #22	I	OT	02/03/2022 06:25AM	1.3	ppb			DG-NH	02/10/2022 08:34PM
2202-01055-030	Drinking fountain room #22	I	DWF	02/03/2022 06:24AM	1.7	ppb			DG-NH	02/10/2022 08:37PM
2202-01055-031	Faucet room #23	I	OT	02/03/2022 06:27AM	1.1	ppb			DG-NH	02/10/2022 08:48PM
2202-01055-032	Drinking fountain room #23	I	DWF	02/03/2022 06:26AM	1.2	ppb			DG-NH	02/10/2022 08:52PM
2202-01055-033	Faucet room #24	I	OT	02/03/2022 06:28AM	2.1	ppb			DG-NH	02/10/2022 08:55PM
2202-01055-034	Drinking fountain room #24	I	DWF	02/03/2022 06:29AM	<1	ppb			DG-NH	02/10/2022 08:59PM
2202-01055-035	Faucet room #25	I	OT	02/03/2022 06:31AM	2.1	ppb			DG-NH	02/10/2022 09:13PM
2202-01055-036	Drinking fountain room #25	I	DWF	02/03/2022 06:31AM	2.7	ppb			DG-NH	02/10/2022 09:17PM
2202-01055-037	Staff room faucet room #27	I	OT	02/03/2022 05:23AM	3.0	ppb			DG-NH	02/10/2022 09:21PM
2202-01055-038	Clinic faucet	I	OT	02/03/2022 05:24AM	<1	ppb			DG-NH	02/10/2022 09:24PM

Rebecca L. Labranche
 Laboratory Director